

Mr. GIRISHKUMAR B. UPADHYAY (FSO- Specialist)

Fire Safety Officer- Specialist, Govt. of Gujarat
FORM B 12 (GFP&LSM -2021 Govt. of Gujarat)
(see sub rule (2) of Rule 21)
Enrolment No.: FSOS/2021/001568
Registered Mobile no: 9879071691
Registered Email ID: girish9791@gmail.com



FORM B 12
(see sub rule (2) of Rule 21)
Enrolment No.: FSOS/2021/001568

FSO/GBU-001568/FS Provision- Audit-042/2025-2026

Dated 30.04.2025

To Whom It May Concern


I as FSO-S inspected for School premises and Conducted Fire Safety Audit of School Building on dated 30.04.2025 of **Jawahar Navodaya Vidyalaya At. Vankal Taluka: Mangarol Dist: Surat- 394430 (Gujarat)** Run under **Ministry Of Education, Govt of India (Department of School Education and Literacy)** for fire safety provision as per as per the Parameter Fire Act GFP&LSM -2013, GFP&LSM rule-2014 & GFP&LSM regulation -2023 and the amendments.

As per NBC and Gujarat Fire Act GFP&LSM-2013, NBC -2016 and GFP&LSM regulation-2023 minimum requirement below 9 Mtr. And one floor 500 Sq. Mtr. School building is only Fire Extinguishers & Hose Reel has to installed in the said school building.

Here I confirm there no any Fire Hazard or Potential Fire Risk Found for life safety of student and Teacher in the School building. School Building Is free from Adjunct other Building and Open Space.

I confirm to Fire Safety Provision and Fire safety Compliance at the Current **Jawahar Navodaya Vidyalaya At. Vankal Taluka: Mangarol Dist: Surat- 394430 (Gujarat)** School Building to the mark and also as per the Parameter Fire Act GFP&LSM -2013, GFP&LSM rule-2014 & GFP&LSM regulation -2023 and there amendments. **Validity of this certificate is one year from the date of issue.**
Dated: 30.04.2025

Place : Surat



Fire Safety Audit Report
No. FS-Pro - Audit - 024
Date: 30.04.2025
Mr. Girishkumar Upadhyay
Fire and Life Safety Auditor
FSO-Specialist-Enrollment
Nos.: FSOS/2021/001568
Dated: 30.04.2025
GSIFST - Govt. of Gujarat

Girish Upadhyay FSO – S Enrolment No.: FSOS/2021/001568