

**Mr. GIRISHKUMAR B. UPADHYAY (FSO- Specialist)**

Fire Safety Officer- Specialist, Govt. of Gujarat  
FORM B 12 (GFP&LSM -2021 Govt. of Gujarat)  
(see sub rule (2) of Rule 21)  
Enrolment No.: FSOS/2021/001568  
Registered Mobile no: 9879071691  
Registered Email ID: girish9791@gmail.com



**FORM B 12**  
(see sub rule (2) of Rule 21)  
Enrolment No.: FSOS/2021/001568

**FSO/GBU-001568/FS Protection- Audit-05/2026-27**

**Dated-19.05.2026**

### **FIRE SAFETY INSPECTION & COMPLIANCE CERTIFICATE**

This is to certify that I, the undersigned **Fire Safety Officer (FSO-S)**, have inspected and conducted a **Fire Safety Audit** of the **Educational Building** namely:

**PM Shri School Jawahar Navodaya Vidyalaya**  
**At: Vankal, Taluka: Mangrol**  
**District: Surat – 394430 (Gujarat)**

The inspection was carried out on **15<sup>th</sup> May, 2026** in accordance with the provisions of:  
**Gujarat Fire Prevention & Life Safety Measures Act, 2013 (GFP&LSM Act-2013)**

- **GFP&LSM Rules-2014**
- **GFP&LSM Regulations-2023 (with amendments)**
- **National Building Code (NBC) 2016**

#### **Findings:**


- The building height is **below 9.0 meters**.
- The **carpet area of the Educational Building** is **above 500 sq. meters**.
- The **Educational premises** is equipped with **Fire Extinguishers** as per the required norms.

#### **Certification:**

In view of the above and as per the provisions of the **GFP&LSM Act, Rules, and Regulations**, I hereby confirm that:

For school premises with a height **below 9 meters** and carpet area **above 500 sq. meters**, **PM Shri School Jawahar Navodaya Vidyalaya Compliance Approval (FSCA / Fire NOC)** is **not required** as per current norms.

- The **fire safety provisions and compliance norms** presently maintained at **PM Shri School Jawahar Navodaya Vidyalaya** are **satisfactory and up to the prescribed standards**.



**Mr. GIRISHKUMAR B. UPADHYAY (FSO- Specialist)**

Fire Safety Officer- Specialist, Govt. of Gujarat  
FORM B 12 (GFP&LSM -2021 Govt. of Gujarat)  
(see sub rule (2) of Rule 21)  
Enrolment No.: FSOS/2021/001568  
Registered Mobile no: 9879071691  
Registered Email ID: girish9791@gmail.com



FORM B 12  
(see sub rule (2) of Rule 21)  
Enrolment No.: FSOS/2021/001568


Issued under my authority as **Fire Safety Officer (FSO-S)** given **FORM B 12 (GFP&LSM - 2021 Govt. of Gujarat)** (see sub rule (2) of Rule 21) by Gujarat Government to carried out Fire Safety Audit, Compliance Certificate, Inspection, Mock Drill & Training.

The validity of this Audit Certificate is two (2) years from the date of issue, i.e., 19.05.2028, or until any further alteration is made in the premises or change in the occupancy of the building, whichever is earlier.

**(Please Note: This only Inspection certificate Not Consider as Fire Noc or FSQA).**

Place: Surat, Gujarat  
Date: 19.05.2026

(Signature & Official Seal)  
Fire Safety Officer (FSO-S)



Girish Upadhyay FSO – S Enrolment No.: FSOS/2021/001568

Fire Safety Audit Report

No. 05/2026-27  
Date: 19.05.2026  
Mr. Girishkumar Upadhyay  
Fire and Life Safety Auditor  
FSO-Specialist-Enrollment  
Nos.: FSOS/2021/001568  
Dated. 21/10/2021  
GSIFST-Govt. of Gujarat